

**UNIVERSITY OF COLORADO AT BOULDER
PORTER BUSWAY REPLACEMENT PROJECT
PROJECT No. PR004260 DM-PORT**

ADDENDUM NO. 1

NOVEMBER 2, 2009

This addendum includes the following items which are changes, clarifications, additions, and/or deletions that are hereby included as part of the contract documents. This addendum shall be acknowledged in the space provided on the bid form. Failure to do so may subject bidder to disqualification. This addendum forms a part of the Contract Documents and modifies the original documents dated October 21, 2009.

General Information:

1. After-hours work shall be included as normal work hours. No additional compensation will be allowed.
2. Feeder conductor replacement is not required for this bid from fusible busway switches to the loads served.

End of Addendum No. 1