



University of Colorado at Boulder

**Department of Facilities Management
Office of Planning, Design & Construction - Engineering**

1540 30th Street, UCB 453, Boulder, Colorado 80309-0453

Phone: (303) 492-5681

FAX: (303) 492-2921

March 17, 2021

Susan Brock
CU Planning Design, & Construction
1540 30th Street
Boulder, Colorado 80309

RE: Project Variance Request – UCB000111-WLAW-RM 211-KWIP Office remodel

Dear Ms. Brock,

Thank you for submitting a variance request to our standards. The University has reviewed your variance request to allow exception of Section C1010.6 of the Facilities Standards for the above referenced project. The standards review committee has determined to approve this variance request under the following conditions:

- A brace will be installed at the midspan of the new wall to structure.
- The wall will extend at least 6-inches above the drop ceiling.
- The brace is inspected by CU.

Please be aware that this determination is only applicable to this specific variance request and this project. No precedent is being set for future determinations..

Thank you,

Jonathan Akins

Jonathan Akins, P.E.
Campus Civil Engineer
Facilities Management - Engineering and Sustainability
UCB 453
Boulder, Colorado 80309
Phone: 303.492.8306
Fax: 303.492.2921
e-mail: jonathan.akins@colorado.edu