



University of Colorado at Boulder

**Department of Facilities Management
Office of Planning, Design & Construction - Engineering**

1540 30th Street, UCB 453, Boulder, Colorado 80309-0453

Phone: (303) 492-5681

FAX: (303) 492-2921

May 24, 2021

Kevin Beck, LEED AP
Architectural Workshop
2 Kalamath Street
Denver, CO 80223

RE: Project Variance Request – UCB000119 - MULTI - CAS - FY21 - BidPac3 - Ramaley & Benson Lab Bundle

Dear Mr. Beck,

Thank you for submitting a variance request to our standards. The University has reviewed your request for a variance of the tempered water requirement for eyewashes for the above referenced project. The CU Environmental Health and Safety department has reviewed your request and determined that it is better to have an eyewash without tempered water than no eyewash at all. Therefore, the standards committee has determined to allow this variance request. Please be aware that this determination is only applicable to this specific variance request and this project. No precedent is being set for future determinations.

Thank you,

Jonathan Akins

Jonathan Akins, P.E.
Campus Civil Engineer
Facilities Management - Engineering and Sustainability
UCB 453
Boulder, Colorado 80309
Phone: 303.492.8306
Fax: 303.492.2921
e-mail: jonathan.akins@colorado.edu