



University of Colorado at Boulder

**Department of Facilities Management
Office of Planning, Design & Construction - Engineering**

1540 30th Street, UCB 453, Boulder, Colorado 80309-0453
Phone: (303) 492-5681
FAX: (303) 492-2921

November 24, 2020

Mark Lapham
Associate Director, Environmental Health and Safety
University of Colorado at Boulder
1000 Regent Drive (UCB 413)
Boulder, CO 80300

RE: Project Variance Request - UCB000119 - MULTI - CAS - FY21 - BidPac3 - Ramaley & Benson Lab Bundle

Dear Mr. Lapham,

The University has reviewed your variance request on behalf of Architectural Workshop for the above mentioned project and provides the determinations listed below. Please be aware that this determination is only applicable to this specific variance request and this project. No precedent is being set for future determinations.

Variance Request – Allow the addition of Guardian products to the list of approved plumbing fixtures for emergency shower and eye/face wash equipment

Variance Response – This variance request is **approved** as it meets the intent of the standards by complying with ANSI Z358.1 (2014)

Thank you,

Jonathan Akins

Jonathan Akins, P.E.
Campus Civil Engineer
Facilities Management - Engineering and Sustainability
UCB 453
Boulder, Colorado 80309
Phone: 303.492.8306
Fax: 303.492.2921
e-mail: jonathan.akins@colorado.edu