

University of Colorado
CERTIFICATION OF SYSTEM OPERATION

Building:

Date:

Contractor:

System Model:

All operational features and functions of this system were tested and found to be operating properly:

- Smoke detectors tested for Alarm
- Heat detectors tested for Alarm
- Duct Detectors tested for Alarm
- Manual Pull Stations tested for Alarm
- Water Flow Switches tested for Alarm
- Tamper Switches tested for Supervisory
- Pre-Action Low Air for Supervisory
- Pre-Action APS tested for Alarm
- Duct Detector Remote LED/Test Switches
- Audible appliances for audibility and operation
- Visual appliances for operation
- Fan shutdown operations
- Damper operations
- Primary Elevator Recall
- Alternate Elevator Recall
- Elevator Shunt
- Door Holder Operations
- Other
- Other

Department of Facilities Management Fire and Life Safety (Audible and Water Flow)

Signed:

Date:

Department of Facilities Management Fire Systems (Devices and Functions)

Signed:

Date:

Department of Facilities Management

Signed:

Date: